



OFFICE OF THE SENIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, ALWAR

Lab/Tech/(Private)/2025-26/ 46 47

Dated: 27-04-2022

EXAMINATION REPORT OF THE PRIVATE WATER SAMPLES

Issued To,

GR Global Academy
B-Block Surya Nagar
Alwar

District: Alwar
Block/City: Alwar

Ref ID :	17	Lab Sample No. :	17
Reference : Your Letter No. :	0	Source :	Treated
Reference Dated :	21.04.25	Source Location :	B-Block Surya Nagar
Date of Receipt :	21.04.25	Habitation/Ward No. :	Alwar
Name of Sample Taker :	Mr.Sanjay	Village/Colony/Town :	Alwar
Desig. of Sample Taker :	0	Gram Panchayat/City Area :	Alwar
GA-55 Book No. :	019763	Date of Collection :	21.04.25
GA-55 Receipt No. :	0023	Date of Examination :	21.04.25
Amount in Rs. :	297.00	Amount Deposited for :	Chem/Bact Testing of Water Sample
Test Parameters	IS-10500:2012		Test Values of Samples
	Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	
1 pH	6.5 to 8.5	No Relaxation	7.0
2 Turbidity (NTU)	5	15	Clear
3 Colour (Hazen Unit)	1	5	None
4 Odour	Unobjectionable	-	None
5 Total Alkalinity (as CaCO ₃) mg/L	200	600	30
6 Total Hardness (as CaCO ₃) mg/L	300	600	60
7 Calcium (as Ca++) mg/L	75	200	
8 Magnesium (as Mg++) mg/L	30	100	
9 Chloride (as Cl ⁻) mg/L	600	1000	20
10 Sulphate (as SO ₄ ⁻²) mg/L	200	400	0
11 Nitrates (as NO ₃ ⁻) mg/L	45	No Relaxation	3
12 Fluoride (as F ⁻) mg/L	1.00	1.50	0.18
13 Total Dissolved Solids (TDS) mg/L	500	2000	98
14 Residual Chlorine (mg/L)	0.20	1.00	-
15 Total Coli Form/100 ml.	NIL/100 ml.	NIL/100 ml.	0
16 E-Coli/ 100 ml.	NIL/100 ml.	NIL/100 ml.	-

(*) The Sample was not collected by this Laboratory.

(**) Not valid for water quality legal cases.

Lab/Tech/(Private)/2025-26/

Copy to:

- 1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.
- 2
- 3

Senior Chemist
PHED, Lab, Alwar
Dated:

Safe Water is Life

Senior Chemist
Save Water Save Life

CHIEF MEDICAL & HEALTH OFFICER ALWAR

SAFE DRINKING WATER AND SANITARY CONDITON CERTIFICATE

NO. Chief / 2025 / 255

Date: 28/04/2025

It is certified that an inspection team headed by Dr. Yogendra kumar Sharma chief medical & health officer alwar inspected The GR Global Academy, Surya Nagar-B, Alwar and found that The GR Global Academy has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central / State Govt.

This certificate is valid till 31 March 2026.

(Dr. Yogendra kumar Sharma)
CHIEF MEDICAL & HEALTH OFFICER
ALWAR

To
GR Global Academy,
Surya Nagar-B,
Alwar